



Procurement and Contracting Services

**Request for Bids for The Replacement of Relays
and Associated Work In The Central
Refrigeration (CRB) and Biotech Medium Voltage
Switchgear.**

ADDENDUM #1

**Please mark all proposal submission
Envelopes with the following information**

**Sealed RFB # S272403
Due on November 22, 2024, no later than 2:00 PM, MST**

The following questions were received prior to the close of the Technical Question period on November 8, 2024, at 12:00 PM MST:

1. Will the current drawings be made available?
 - a. Refer to paragraphs 5.2 E and Actions Submittals 1.3.B.6 of RFB “5.0 Scope of Work, Specifications, Technical Requirements.”
2. Per 5.1 its states that the project must be completed, installed, and fully operational no later than October 31, 2025. During the job walk it was mentioned that the project can only take place during winter months. Can you please clarify if this is a hard date? If so, we will have to approach this project at the beginning of 2025.
 - a. Yes, we will determine “completion date” after RFB is awarded.
3. Is it possible to have a few minutes on site to take exact measurements of the doors to get pricing on sheet metal? If not, is this something the university can supply?
 - a. Personnel can be available Nov. 13, 14, 18 between 7am-10am. Please email Talaney Garth at tgarth@arizona.edu to coordinate, if needed.
4. Was U of A able to locate past testing results on the current relays?
 - a. UA has no records for relay testing or settings.
5. Do you have a current coordination study of the 3 line ups?
 - a. Yes, coordination study will be provided to awarded RFB.

End of addendum, all else remains the same.